



Republic of the Philippines
DEPARTMENT OF HEALTH
Center for Health Development for Davao Region
Southern Philippines Medical Center
J. P. Laurel Avenue, Davao City
Tel. Nos. 227-27-31; Fax No. 221-7029



BID BULLETIN NO. 1

(August 2, 2019)

Air conditioning Unit (ACU) Installation at IPBM-OPD Building

Bid No: 2019-07-0390 (ABC NO. 2019-007)

This BID BULLETIN No. 1 is issued to modify or revise some items of the *Technical Specifications* of the abovementioned project. This modification shall prevail and form an integral part of the Bidding Documents.

1. Technical Specifications:

a. In page 2

- The highlighted specification were added for the **NINE (9) SETS AIR CONDITIONING UNIT**, as follows:
 - Split Type
 - **At least 2.0Hp**
 - **Ceiling** Cassette Mounted
 - Inverter Type
 - 220Vac/60Hz)
 - Should include installation


b. In page 3

- The highlighted specification were added for the **SEVEN (7) SETS AIR CONDITIONING UNIT**, as follows:
 - Split Type
 - 3.0Tonner
 - **Ceiling** Cassette Mounted
 - Inverter Type
 - 220Vac/60Hz
 - Should include installation
- The highlighted specification were added for the **TWO (2) UNITS AIR CONDITIONING UNIT**, as follows:
 - Split Type

- 5.0 Tonner
 - **Ceiling** Cassette Mounted
 - Inverter Type
 - 220Vac/60Hz **3 or 1 Phase**
 - Should include installation
- c. In page 5, the "*for split type*" has been deleted in the specification and now reads, "*With R410A or equivalent refrigerant*".
- d. In page 6 the requirements for items 1 and 2 under the Other Terms and Conditions has been revised, as follows:
1. The equipment must be BRAND-NEW. Supplier must conduct preventive maintenance of the equipment without additional cost to the hospital and maintains the equipment in the same good condition, including the following services:
 - a. Free cleaning every three months for one (1) year.
 - b. Free installation within 10 feet (in excess of 10 feet, the hospital will **pay separately for the cost of the materials used in the installation**).
 - c. Free repair including parts, **materials** and service during warranty.
 - d. **Free installation of the electric fans.**
 2. The warranty period will commence upon the acceptance of the equipment/machines.
 - 2.1 Window Type Warranty:
 - Compressors - **at least Five (5) Years**
 - Other Parts **and services – at least One (1) Year**
 - 2.2 Split Type Floor and Ceiling Mounted Warranty:
 - Compressor, Other Parts **and services – at least One (1) Year**
 - 2.3 **Electric Fans - at least One (1) Year**
2. Due to many items in the technical specifications that were revised, a revised technical specification shall be issued to prospective bidders who have bought the bidding documents. The revised technical specification must be submitted during the bid opening.

All other provision of the bidding documents which are not affected shall remain in effect.

For guidance and information of all concerned.


ATTY. DANILO A. CULLO
 Chairman, Bids and Awards Committee