



BID BULLETIN NO. 1

(December 14, 2018)

Supply, Delivery and Installation of Split Type Air Conditioning System at SPMC Main Building (for NICU, Delivery Room and OB-Gyne Wards)
Bid No: 2018-11-0930 (ABC NO. 2018-071)

This BID BULLETIN No. 1 is issued to modify or revise some items indicated in the *Technical Specifications* of the abovementioned project. This modification shall prevail and form an integral part of the Bidding Documents.

1. Technical Specifications

- a. In page 3, add R410A and the specification becomes *"With R22 / **R410A** refrigerant for split type"*.
 - b. In page 4 item 3 under the Other Terms and Conditions, revise the requirement and becomes *"The equipment / machine must be able to comply with its installation and operation qualification which would be conducted in the presence of **Air conditioning Technician**, End-user and the Company Engineer"*.
 - c. In page 5 item 7 under the Warranty Period, delete *"Window Type Warranty"*.
2. A Plan or Lay out will be provided to the prospective bidders to provide guidance on where to install the air conditioning system.

All other provision of the bidding documents which are not affected shall remain in effect.

For guidance and information of all concerned.


RICARDO S. JUSTOL, MARE, MPA
Chairperson, Bids and Awards Committee