



Republic of the Philippines
Department of Health
Regional Office No. XI
SOUTHERN PHILIPPINES MEDICAL CENTER
J.P. Laurel Avenue, Davao City



TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

Instructions:

Bidders must state in the column under **Statement of Compliance** the word either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of **ITB** Clause 3.1(a) (ii) and/or **GCC** Clause 2.1(a) (ii).

Bidder may submit offer which provides for superior specifications and /or better terms and conditions to the government at no extra cost. However, these shall not be given any bonus, credit or premium in the bid evaluation

Prepared by Technical Working Group

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non-completion of Statement of Compliance for the item included in its bid shall be considered **non-responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u>	Supply, Delivery and Installation of at least (1x1000KVA) Diesel Generator; 220-240Vac; 3-Phase; 60Hz; 0.8PF; Powered by heavy duty Diesel Engine; 1800RPM; 4-Stroke; Turbo-charged with after cooler directly coupled to heavy duty brushless type AC Alternator with at least 3000Ampere Compatible Automatic Transfer Switch (ATS), with SCADA/HMI compatible to existing monitoring system, Powerhouse and Wirings. (FOR SPMC MAIN BUILDINGS REPLACEMENT UNIT).		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<p>A. GENERATING SET:</p> <ol style="list-style-type: none"> 1. 24 Volt electric start with 24 VDC charging alternator 2. Unit mounted Digital Microprocessor Generator Control Panel with LCD Display for following: <ul style="list-style-type: none"> - AC Output Voltmeter, Ammeter and Frequency Meter - Digital Engine protection device and alarms for low oil pressure, water high temperature, over speed, DC charge fault and emergency stop. - Engine Pressure, Water Temperature & Running Hours Meter - Digital Auto Start/Stop Device & Cool Down Module w/ Start Switch and Auto/Manual Selector - Electronic Type Speed Controller - Remote Interface for RS323 or Modem for Computer monitoring and control 3. Skid mounted, direct coupled engine to generator with soundproof weather protective canopy 		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<ol style="list-style-type: none"> 4. Unit mounted type heavy duty radiator w/ engine driven cooling fan with protection guard 5. Heavy duty steel base with built-in rubber vibration isolator 6. Heavy duty compatible industrial type turbocharger 7. Fuel, Lubricating Oil and Air Filter(s) with Restriction Indicator(s) 8. Flexible rubber joints for fuel and lube oil drain 9. With Generator Circuit Breaker, 3-pole, manually operated fixed type 10. Branded/Heavy Duty Type with Bus Bar and NEMA 1 metal enclosure 11. Set mounted with heavy duty maintenance free lead acid battery with leads and terminals 12. Complete with standard accessories 13. With Automatic Battery Charger (At least 5A, w/ 24Vdc output and 220Vac Single Phase Input 14. With Radiator Coolant and Engine Lube Oil 15. With Flexible Exhaust Pipe (Stainless Type) 16. Wiring to Control Panel 		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non-completion of Statement of Compliance for the item included in its bid shall be considered **non-responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<p>17. Steel base frame with integral 8-hour capacity fuel tank, complete with contents gauge, steel wire braded fuel lines, fill, vent and drain fittings.</p> <p>18. With Exhaust Silencer, Hospital Grade Type (at least 55dBA @100m)</p> <p>19. Conduct load and function tests (must pass the standard requirements)</p> <p>20. Paint finish according to standard painting scheme</p> <p>B. AUTOMATIC TRANSFER SWITCH (ATS):</p> <ol style="list-style-type: none"> 1. At least at compatible Ampere Ratings per unit, 3-phase, 3 or 4 poles, 220V, 60Hz, Motor Operated Circuit Breaker. Intelligence Circuit 2. With Under/Over Voltage Sensor 3. With Time Delay 4. With Auto/Manual Switch 5. With Test Switch 6. With NR & ER Relay 7. With Single Phasing Voltage Sensor 		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<p>C. INSTALLATION WORKS:</p> <ol style="list-style-type: none"> 1. Complete supply, delivery of materials and construction of genset power house for SPMC –Main Building including generator base. 2. Complete supply, delivery and installation of mechanical parts and accessories. 3. Complete supply, delivery and installation of electrical parts, panelboards & breakers, ATS, wires/cables including insulations and accessories. 4. Complete supply, delivery and installation of civil and related works necessary for generating set installation. 5. Complete supply, delivery and installation of CCTV and SCADA/HMI and to be connected to existing monitoring system. (CCTV must be compatible to the existing CCTVs in the Security Services) 6. Complete supply, delivery and installation of ventilation requirements of power house. 7. Complete processing of government permits needed for generating set operation. 		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<p>OTHER TERMS AND CONDITIONS OF ACCEPTABILITY:</p> <ol style="list-style-type: none"> 1. All equipment/machines must be manufactured by a known and reputable company with Certificate of Good Manufacturing Practice (GMP), TUV or ISO or its equivalent for equipment/machine only. 2. Supplier must process and provide all government permits needed for equipment/machine operation. 3. Supplier must provide preventive maintenance/calibration of the equipment/machine as warranted without cost to the hospital and maintain in the same good condition including the following: <ol style="list-style-type: none"> a. Free repair including parts and service during warranty period. b. Quarterly preventive maintenance during warranty period. 4. The supplier must provide three (3) complete sets of the Operating and Service Manuals in English including parts catalog. 5. Supplier must either be the exclusive or authorized distributor of the principal company of the equipment/machine and the necessary parts/accessories in the Philippines. 		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p style="text-align: center;"><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p style="text-align: center;"><i>(continuation)</i></p>	<p>6. The warranty period must be two (2) years and will commence after acceptance of the equipment/machines.</p> <p>7. Supplier must guarantee the following:</p> <ul style="list-style-type: none"> a. To have service engineer or technical personnel based in Davao City or Mindanao. b. To provide 24hours/day and 7days/week service support for emergency calls. c. To provide a substitute technical personnel and/or specialist in cases where the assigned service engineer is out of town. <p>8. The end-user and technician must have an actual inspection and or witness an actual installation and commissioning of the equipment/machine being offered.</p> <p>9. Supplier's technical personnel shall train the designated operator(s) of the equipment/machine and technician(s) onsite, until they can handle the equipment/machine confidently with no additional cost to the procuring entity. Supplier must submit a comprehensive training module as part of the technical specification which covers product orientation, hands-on training and troubleshooting. The said training must be conducted by a certified product specialist. The module should indicate the following:</p>		

Name and Signature of Authorized Representative

TECHNICAL SPECIFICATIONS

SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET

Name of Project

The bidder is required to complete its Statement of Compliance demonstrating how its items complied with the specification. Non- completion of Statement of Compliance for the item included in its bid shall be considered **non- responsive** for that item.

<i>Item</i>	<i>Procuring Entity's Specification</i>	<i>Bidder's Specification as Technical Offer</i>	<i>Statement of Compliance</i>
<p><u>SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT BRAND NEW (AT LEAST) 1X1000 KVA GENERATING SET</u></p> <p><i>(continuation)</i></p>	<ul style="list-style-type: none"> a. The objectives of the training b. The methods or activities that shall be done during the training c. The training outline that indicates the concepts and/or skills to be discussed/ taught. d. The target participants of the training e. The activity schedule indicating the no. of days or hours <p>10. In case of machine downtime, the supplier shall:</p> <ul style="list-style-type: none"> a. Do remedial action (repair and or replacement of spare parts) within two (2) days. b. On the third day. If equipment/machine or system is not operational, a back-up unit will be provided within the warranty period. The supplier will be given 14 days to comply in providing back up machine. A penalty will be imposed after the 14th day amounting to the average daily income of the machine. This is to cover for the income loss. <p>11. The Southern Philippines Medical Center has the right to terminate the contract for any violation in the right to terminate the contract for any violation in the terms and conditions stated in this technical specification and other reasons as stated in the GCC.</p>		

The Bidder may submit offer which provides for superior specifications and/or better terms and conditions to the government at no extra cost. However, these shall not be given any bonus, credit or premium in the bid evaluation.

Name and Signature of Authorized Representative

